# POWER GENERATION APPLICATIONS | Power Generation Applications | Power Generation | Power

N45 TM2A 96 kW @ 1500 rpm 107 kW @ 1800 rpm

Stage II **Specifications** Thermodynamic cycle Diesel 4 stroke Air intake TAA Arrangement 4L Bore x Stroke 104 x 132 mm Total displacement 4.5 Valves per cylinder 2 Mechanical Injection system Speed governor mechanical liquid (water - paraflu 50%) Cooling system Flywheel housing/flywheel SAE3 / 11" 1/2 type Direction of rotation (seen from flywheel side) CCW Oil specifications ACEA E3-E5 Oil consumption <0.1% of fuel consumption Fuel specifications EN 590 Oil and filter maintenance interval for replacement 600 hours Specific fuel consumption at: 1500 1800 rpm 100% load I/h (g/kWh) 22.0 (207.7) 26.3 (221.0) 80% load I/h (g/kWh) 16.2 (203.5) 19.6 (220.0) 50% load I/h (g/kWh) 11.0 (206.5) 13.5 (226.0) ~8.5 Coolant capacity: engine only engine+radiator ~18.5 50 ATB (without canopy) No remote cooling radiator allowed ~12.8 Lube oil total system capacity including pipes, filters etc. Electric system 12 Vcc 1 x 100 Starting batteries: recommended capacity Ah Discharge current (EN 50342) Α 650

#### **Performances**

Cold starting: without air preheating

with air preheating

Ratings <sup>1</sup>			1500 rpm		1800 rpm	
		PRIME	STAND-BY	PRIME	STAND-BY	
Rated Output <sup>2</sup>	kWm	87	96	97	107	

°C

°C

-10

-25

**PRIME POWER:** The prime power is the maximum power available with varying loads for an unlimited number of hours. The average power output during a 24h period of operation must not exceed 80% of the declared prime power between the prescribed maintenance intervals and at standard environmental conditions. A 10% overload is permissible for 1 hour every 12 hours of operation.

**STAND-BY POWER:** The stand-by power is the maximum power available for a period of 500 hours/year with a mean load factor of 90% of the declared stand-by power. No kind of overloads is permissible for this use.

**CONTINUOUS POWER:** Contact the FPT sales organization.



<sup>1)</sup> Ratings in accordance with ISO 8528. For duty at temperature over 40°C and/or altitude over 1000 meters must be considered a power derating factor. Contact the FPT sales organization.

<sup>2)</sup> Net power at flywheel available after 50 hours running with a  $\pm 3\%$  tolerance.

# 96 kW @ 1500 rpm 107 kW @ 1800 rpm Stage II

## **Standard configuration**

FPT engine N45 TM2A equipped with:

- Mounted radiator incorporating air-to-air charge cooler
- Mounted belt driven pusher fan
- Fan guard
- Mounted air filter with replaceable cartridges
- Fuel filter
- Primary fuel filter/water separator
- Replaceable oil filter
- Front engine mounting brackets
- Flywheel housing SAE3 and flywheel 11"1/2
- Redirectable exhaust gas elbow
- Recirculed oil breather system
- Oil dipstick
- HWT and LOP sensors
- 12 Vdc electrical system
- User's handbook

THE ENGINE IS SUPPLIED WITHOUT LIQUIDS

## **Optional equipment:**

On request the engine can be supplied with:

- Oil drain pump
- Oil drain valve
- 120/230 Volt water jacket heater
   WT and OP sensors for gauges
- Low water level sensor
- Turbo and exhaust gas guards Exhaust gas flexible joint 24 Vdc electrical system

#### **Overall dimensions:**





